

G1805 Eyewash, Deck Mounted AutoFlow™ 90° Swivel, Right Hand Mounting G1805LH Eyewash, Deck Mounted AutoFlow<sup>™</sup> 90° Swivel, Left Hand Mounting



**Application:** AutoFlow<sup>™</sup> eyewash for mounting next to sink. Swinging the spray head assembly horizontally out over the sink activates the water flow. The unit remains in operation until the spray head assembly is swung back into the storage position, closing the valve.

**Spray Head Assembly:** Two GS-Plus<sup>™</sup> spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from the water flow.

**Valve:** 1/2" IPS plug-type valve with Teflon<sup>®</sup> coated O-ring seals. Swinging head assembly from storage to operational position opens orifice and activates water flow. Unit remains in operation until head assembly is returned to storage position.

Strainer: Unit is furnished with in-line strainer to protect valve and spray heads from debris in water line.

Mounting: Unit may be mounted on right side (G1805) or left side (G1805LH) of sink. Furnished with mounting shank, positioning lugs, locknut and washer for securing unit to counter.

Construction: Polished chrome plated brass.

Supply: 1/2" NPT female inlet.

Sign: ANSI-compliant identification sign.

Quality Assurance: Unit is completely assembled and water tested prior to shipment.

## **Available Options**

**DC** Stainless steel dust cover for each spray head.

TMV G3600LF thermostatic mixing valve precisely blends hot and cold water to deliver warm (tepid) water as required by ANSI Z358.1-2014. Refer to "Tempering Units" section for complete technical and product selection information.

312 447 8100 телерноме gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code. C










G1805 Eyewash, Deck Mounted AutoFlow™ 90° Swivel, Right Hand Mounting □ G1805LH Eyewash, Deck Mounted AutoFlow<sup>™</sup> 90° Swivel, Left Hand Mounting



Guardian Equipment 1140 N North Branch St Chicago, IL 60642

312 447 8100 TELEPHONE 312 447 8101 FACSIMILE gesafety.com

Listed 8116. Units have been tested to and comply with ANSI 7358.1-2014 and the Uniform Plumbing Code.







ETL Listed 101496. Units have been tested to and comply with ANSI Z358.1-2014.