



**G1902** Safety Station with Eyewash, Stainless Steel Bowl

**Application:** Combination eyewash and shower safety station. Two GS-Plus™ spray-type outlet heads deliver a flood of water for rinsing eyes.

**Shower Head:** 10" diameter orange ABS plastic.

**Shower Valve:** 1" IPS chrome plated brass stay-open ball valve. Valve is US-made with chrome plated brass ball and Teflon® seals. Furnished with stainless steel actuating arm and 29" stainless steel pull rod.

Spray Head Assembly: Two GS-Plus™ spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from water.

Eyewash Bowl: 11-1/2" stainless steel.

**Eyewash Valve:** 1/2" IPS chrome plated brass stay-open ball valve. Valve is US-made with chrome plated brass ball and Teflon® seals.

Pipe and Fittings: Schedule 40 galvanized steel. Furnished with orange polyethylene covers for vertical piping for high visibility and corrosion resistance.

**Supply:** 1-1/4" NPT female top or side inlet.

Waste: 1-1/4" NPT female outlet. Outlet can be positioned at either 9-1/4" or 19-5/8" above finished floor by reversing lower pipe nipples.

**Sign:** Furnished with ANSI-compliant identification sign.

**Quality Assurance:** Valve and spray head assemblies are factory assembled and water tested prior to shipment.

## **Available Options**

☐ GC Powder coated finish on galvanized Pipe and Fittin Available colors include orange, yellow, red and green.
FC20 Regulates shower flow rate to 20 GPM.
GRN Green ABS plastic shower head.
☐ <b>YEL</b> Yellow ABS plastic shower head.
SSH Stainless steel shower head.
AP275-100 Electric Light and Alarm Horn Light and alarm horn summon assistance when eyewa or shower is activated.
AP250-015 Modesty Curtain Modesty curtain for mounting on safety station.

**TMV** G3800LF thermostatic mixing valve precisely blends hot and cold water to deliver warm (tepid) water as






required by ANSI Z358.1-2014.



## **G1902** Safety Station with Eyewash, Stainless Steel Bowl



THIS SPACE FOR ARCHITECT/ENGINEER APPROVAL

Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are  $\pm$  1/4" (6mm).



UPC listed 8116. ETL listed 101496. Units have been tested to and comply with ANSI Z358.1-2014.

