spirax sarco


TD62LM and TD62M Thermodynamic Steam Trap with replaceable seats

Description

The TD62LM and TD62M are maintainable high pressure thermodynamic steam traps with integral strainer and a replaceable seat to ease maintenance. They have been specifically designed for mains drainage applications up to 62 barg.

The TD62LM is specifically designed for relatively small condensate loads on superheat and mains drainage applications. An insulating cover is fitted as standard to prevent the trap being unduly influenced by excessive heat loss when subjected to low outside temperatures, wind, rain etc.

Model	TD62LM and TD62M			
РМО	900 psig			
Sizes	1/2", 3/4", 1"			
Connections	SW to ANSI B16.11 Class 3000			
Construction	Alloy Steel			
Options	NPT Connections ANSI 600 Flanged Blowdown Valve (SW and NPT onl			



Capacities


Hot Condensate Flow							
Pressure		TD62	LM	TD62M			
psig 25	barg	#/hr.	kg.hr.	#/hr. 293	kg.hr 133		
	2						
50	3			422	192		
100	7			552	250		
120	8	167	76	586	266		
150	10	185	84	628	285		
200	14	212	96	682	309		
250	17	235	107	724	328		
300	21	256	116	758	344		
350	24	274	124	786	357		
400	28	292	132	811	368		
500	34	324	147	853	387		
550	38	338	153	871	395		
600	41	352	160	887	402		
650	45	366	166	902	409		
700	48	378	172	916	415		
750	52	391	177	929	421		
800	55	402	183	941	427		
850	59	414	188	952	432		
900	62	425	193	963	437		

Materials

IAIC	Materials					
No.	Part	Material				
1	Body	Steel	ASTM A217 Gr. WC 6			
2	Cover	Steel	ASTM A217 Gr. WC 6			
3	Strainer cap	Steel	ASTM A217 Gr. WC 6			
4	Strainer screen	Stainless steel 100 m	esh 316L			
5	Insulating cover	Aluminium				
6	Disc	Chromium steel				
7	Seat	Chromium steel				
8	Cover studs	Steel	ASTM A193 Gr. B16			
9	Cover nuts	Steel	ASTM A194 Gr. 8M			
10	Cover gasket	Spirally wound stainless steel				
		with exfoliated graphi	te filler			
11	Name-plate	Stainless steel				
12	Strainer cap gaske	t Reinforced exfoliated	d graphite			
13	Inner seat gasket	Spirally wound stainle	ess steel			
		with exfoliated graphi				
14	Outer seat gasket	Spirally wound stainle	ess steel			

15 Ferrule Stainless steel

Operating Range (SW Connection Only)



The product must not be used in this regio

* PMO — Max. operating pressure recommended PMOB — Max. operating back pressure 80% of upstream pressure

Limiting Conditions

Body design conditions ANSI 600

PMA – Max. allowable pressure 1500 psig 103 barg
TMA – Max. allowable temperature 977°F 525°C
Cold hydraulic test pressure 2250 psig 155 barg

with exfoliated graphite filler


TD62LM

Minimum pressure for satisfactory operation is 120 psig, 8 barg. Maximum back pressure should not exceed 50% of the inlet pressure under any conditions of operation, otherwise the trap may not shut. **TD62M**

Minimum pressure for satisfactory operation is 20 psig, 1.4 barg. Maximum back pressure should not exceed 80% of the inlet pressure under any conditions of operation, otherwise the trap may not shut.

^{*} Note: Item 15 (ferrule) is pressed into item 7 (seat).

TD62LM and TD62M Thermodynamic Steam Trap with replaceable seats




Dim	ens	ANSI 600	(nomi ANSI 300	nal) in	inche	s and	millim	eters
Size	Α	B1	B2	С	D	E	F	Weight
1/2"	3.2	5.9	5.3	3.6	2.8	1.6	1.2	18.7 lb
	82	150	135	92	72	40	30	8.5 kg
3/4"	3.2	5.9	5.4	3.6	2.8	1.6	1.2	18.7 lb
	82	150	138	92	72	40	30	8.5 kg
1"	3.2	6.3	5.8	3.6	2.8	1.6	1.2	20.0 lb
	82	160	147	92	72	40	30	9.1 kg

Sample Specification

Spirax Sarco TD62M Thermodynamic steam trap, available in sizes 1/2", 3/4", and 1" socket weld connections to ANSI B16.11 Class 3000 (or NPT or ANSI 300 or 600 flanged connections). Alloy steel construction, suitable for operation from 20 to 900 psig at a maximum operating temperature of 842°F. An integral strainer and insulating cover are standard. Traps to have replacement seats and disc.

Installation

The preferred trap installation is in a horizontal pipe with the insulcap up. After 24 hours in service the cover nuts should be checked for tightness and if necessary torqued to 33-37 ft•lb. Full-port isolating valves should be installed upstream and downstream of the trap.



Spare Parts

The spare parts available are shown in solid outline. Parts shown in broken line are not supplied a spares.

Available spares

•		
Insulating cover		5
Set of cover studs and nuts (set of 8) on FCC	4 on other	8, 8A, 9
Seat and disc assembly	6, 7, 10, 13, 14, 15	
Strainer screen 100 mesh		4
Cover gasket (packet of 3 sets) Flanged		10,13,14
Set of gaskets (packet of 3 sets) SW, NPT	10	0,12,13,14

How to order spares

Always order spares by using the description given in the column headed "Available spares" and state the size and type of trap.

Example: 1- Strainer screen for a Spirax Sarco 1" TD62LM thermodynamic steam trap (ASTM body)

Maintenance

This product can be maintained without disturbing the piping connections. Complete isolation of the trap from both supply and return line is required before any servicing is performed. The trap should be disassembled periodically for cleaning of the strainer screen and inspection and cleaning of the disc and seat. Complete installation and maintenance instructions are given in the IMI Sheet, which accompanies the product. (IM-P068-58)

TI-2-525-US 6.17

2017

Spirax Sarco,